

ಬರಗೂರು ಗ್ರಾಮ ಪಂಚಾಯಿತಿ ಕಾರ್ಯಾಲಯ

ಬರಗೂರು, ಶಿರಾ ತಾಲ್ಲೂಕು, ತುಮಕೂರು ಜಿಲ್ಲೆ.

ದಿನಾಂಕ:10.02.2023

ಆರೋಗ್ಯ ಮತ್ತು ಸ್ವಾಸ್ಥ್ಯ ಪ್ರಮಾಣ ಪತ್ರ

ಶಿರಾ ತಾಲ್ಲೂಕು ಬರಗೂರು ಗ್ರಾಮ ಪಂಚಾಯಿತಿ ವ್ಯಾಪ್ತಿಯ ಬರಗೂರು ಗ್ರಾಮದಲ್ಲಿರುವ 'ದಿ ಫ್ಲಾರೆನ್ಸ್ ಪಬ್ಲಿಕ್ ಸ್ಕೂಲ್', ಕೆ.ಇ.ಬಿ. ಮೆಮೋರಿಯಲ್ ಎಜುಕೇಷನಲ್ ಟ್ರಸ್ಟ್ (ರಿ), ಇದರ ವತಿಯಿಂದ ನಡೆಯುತ್ತಿದ್ದು ಸದರಿ ಸ್ಕೂಲ್‌ನಲ್ಲಿ ಸ್ಯಾನಿಟರಿ ಮತ್ತು ಫ್ಲಂಬಿಂಗ್ ಸಂಪರ್ಕ ಸಮರ್ಪಕವಾಗಿದ್ದು ಶಾಲಾ ಚಟುವಟಿಕೆಗಳನ್ನು ನಿರ್ವಹಿಸಲು ಸೂಕ್ತ ಸ್ವಾಸ್ಥ್ಯ ಹೊಂದಿದೆ ಎಂದು ಈ ಮೂಲಕ ಪ್ರಮಾಣೀಕರಿಸುತ್ತೇನೆ. ಸದರಿ ಪ್ರಮಾಣ ಪತ್ರವು ದಿನಾಂಕ: 10-02-2023 ರಿಂದ 10-04-2024 ರವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ.

Mylappa
PRINCIPAL

THE FLORENCE PUBLIC SCHOOL
Baraguru, Sira Tq, Tumkur Dist.

ಅಧ್ಯಕ್ಷರು
ಸಹಿ ಮತ್ತು ಮುದ್ರೆ
ಶಿರಾ ತಾಲ್ಲೂಕು

For K E B MEMORIAL EDUCATIONAL TRUST

Principath
Sole Trustee

OFFICE OF THE VILLAGE PANCHAYATH: BARAGURU

Baraguru village, Shira Taluk, Tumkur
District.

CERTIFICATE
of
Health and healthiness

The FLORENCE PUBLIC SCHOOL is running or administered by M/s. K.E.B. Memorial Educational Trust (R) at or within the jurisdiction of Baraguru village panchayath limits, Baraguru, Shira Taluk. The Sanitary and public facilities or connections provided to the school is satisfactory. The school got the good and healthy environment. It is certified accordingly.

This certificate will be valid from 10.02.2023 to 10.04.2024.

Sd/-
(LAKSHMANA)

PRESIDENT

Baraguru village panchayath
Baraguru
Shira Taluk.



Translated from *Kannada* English
by K.M.BHAT
Stall No 80, Typing Pool, D.C. Commission
K.G. Road, Bangalore - 560 009
MOB No: 9443304583 20/2/2023

For K.E.B MEMORIAL EDUCATIONAL TRUST

Sole Trustee

ATTESTED BY ME

B.K.R. KRISHNAMURTHY
M.A., B.Ed., M.Com., M.L.,
NOTARY - Reg. No. 1351
GOVT. OF INDIA, B'LORE-9

Myloppa
PRINCIPAL
FLORENCE PUBLIC SCHOOL
Baraguru, Sira Tq, Tumkur Dist.

ULR Number	TC8828230000000274F		
Sample Number	PL/W/23-24/0324	Report Date	12 June 2023
Customer details	The Florence Public School Baraguru, Sira Taluk, Tumkur district-572113		
Sample Details	Drinking Water		
Sample Condition	Good	Sample Received date	07 June 2023
Sample Package	NA	Analysis Started on	07 June 2023
Sample provided by	Customer	Analysis Ended on	12 June 2023

Sl. No.	Parameters	Test method	Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Odour	IS : 3025 (part 5)	Agreeable	Agreeable
2	Turbidity	IS : 3025 (part 10)	<0.5	Maximum 1 NTU
3	pH Value	IS : 3025 (part 11)	7.3	6.5 – 8.5
4	Total Dissolved Solids	IS : 3025 (part 16)	236	Maximum 500 mg/L
5	Total Hardness as CaCO ₃	IS : 3025 (part 21)	52	Maximum 200 mg/L
6	Calcium as Ca	IS : 3025 (part 40)	16	Maximum 75 mg/L
7	Magnesium as Mg	IS : 3025 (part 46)	3	Maximum 30 mg/L
8	Chloride as Cl	IS : 3025 (part 32)	32	Maximum 250 mg/L
9	Total Alkalinity as CaCO ₃	IS : 3025 (part 23)	120	Maximum 200 mg/L
10	Sulphates as SO ₄	IS : 3025 (part 24)	16	Maximum 200 mg/L
11	Fluoride as F	IS : 3025 (part 60)	0.1	Maximum 1 mg/L
12	Iron as Fe	IS : 3025 (part 53)	<0.1	Maximum 1 mg/L
13	Total Coliform Bacteria	IS : 15185 : 2016	Absent	Shall not be detectable in 100 mL sample
14	E.Coli	IS : 15185 : 2016	Absent	

Inference: The given sample conforms to IS 10500:2012 Drinking water specification (Acceptable limit) for the above tested parameters.

- Note:**
1. The results listed refer only to the tested sample and applicable parameters.
 2. In case of dispute our liability is limited to the billed amount received by us.
 3. Samples will be preserved for 15 days on request. Food samples and microbiology samples will be discarded after analysis.
 4. This certificate shall not be reproduced except full without approval of the laboratory and cannot be used as evidence in the court of law.

Suprita Behera
Authorized Signatory
Suprita Behera
Senior Associate- Prewel Labs
Microbiology
BANGALORE

Mahadeva M J
Authorized Signatory
Mahadeva M J
Assistant Manager- Prewel Labs
Chemistry
BANGALORE

Page No. 01 of 01



M. S. Prasad
PRINCIPAL
THE FLORENCE PUBLIC SCHOOL
Baraguru, Sira Tq, Tumkur Dist.

For K E B MEMORIAL EDUCATIONAL TRUST
[Signature]
Trustee

TEST REPORT

PL/FOR/016/01

Sample Number	PL/W/23-24/0324	Report Date	12 June 2023
Customer details	The Florence Public School Baraguru, Sira Taluk, Tumkur district-572113		
Sample Details	Drinking Water		
Sample Condition	Good	Sample Received date	07 June 2023
Sample Package	NA	Analysis Started on	07 June 2023
Sample provided by	Customer	Analysis Ended on	12 June 2023

Sl. No.	Parameters	Test method	Results	IS 10500 : 2012 Drinking water specification requirement (Acceptable limit)
1	Colour	IS : 3025 (part 4)	<5	Maximum 5 Hazens
2	Nitrate as NO ₃	APHA Method-4500	2	Maximum 45 mg/L
3	Zinc as Zn	IS : 3025 (part 49)	<0.1	Maximum 5 mg/L
4	Aluminium as Al	IS : 3025 (part 55)	<0.02	Maximum 0.03 mg/L
5	Boron as B	IS : 3025 (part 57)	<0.1	Maximum 0.5 mg/L

Inference: The given sample conforms to IS 10500:2012 Drinking water specification (Acceptable limit) for the above tested parameters.

Note:

1. The results listed refer only to the tested sample and applicable parameters.
2. In case of dispute our liability is limited to the billed amount received by us.
3. Samples will be preserved for 15 days on request. Food samples and microbiology samples will be discarded after analysis.
4. This certificate shall not be reproduced except full without approval of the laboratory and cannot be used as evidence in the court of law.

Mahadeva M
Authorized Signatory
Mahadeva M
Assistant Manager- Prewel Labs
Chemistry
BANGALORE

End of the Report

Mylappa
PRINCIPAL
THE FLORENCE PUBLIC SCHOOL
Baraguru, Sira Taluk, Tumkur Dist.

For K E B MEMORIAL EDUCATIONAL TRUST
[Signature]
Sole Trustee

Page No. 01 of 01

Prewel Labs Pvt. Ltd.



+91-63669 42390



CIN : U85300KA2021PTC147708

www.prewellabs.com



#24, 22nd Main Road, Marenahalli, J.P. Nagar 2nd Phase, Bengaluru - 560 078



support@prewellabs.com

